

FIRE SPRINKLER NOTICE

Supplement for Instruction & Prep Sheet for Thermal Treatment

Fire sprinkler systems are activated by heat and must therefore be turned off, drained, and capped prior to the heat treatment service. It is recommended that a certified fire sprinkler company be contracted to perform the following services, which are the sole responsibility of the owner/agent.

- (1) Operating temperatures of the sprinkler heads must be determined and our company must be notified of the temperature ratings in all treatment areas;
- (2) System must be shut off and, if required, notify the fire department and alarm company.
- (3) System must be fully and completely drained and drain valve must be left open during treatment (these 3 steps must be taken before heat service takes place);
- (4) After treatment, the fire sprinkler contractor must inspect all sprinkler heads for damage and replace any damaged heads.
- (5) After inspection by sprinkler contractor, system can be reactivated. Heat contractor will not assume any responsibility or responsibility for damage sustained to sprinkler heads or any resulting water damage.

The undersigned have read, reviewed, and agreed to all the provisions contained herein and have acknowledged receipt of an exact copy of this Instruction & Prep Sheet for Thermal Treatment. In the event that I/we do not comply with the requirements of this notice, **I/we agree to hold harmless (Pest Control Operator/Contractor) and its affiliates and sub-contractors involved in the completion of said treatment service, harmless of any liabilities connected with this treatment and further allow (Pest Control Operator/Contractor) and its affiliates and sub-contractors to protect fire sprinkler heads.**

Owner/Manager Signature

Title

Date